

**To:** Stetler, Chris@waterboards.ca.gov  
(Chris.Stetler@waterboards.ca.gov)[Chris.Stetler@waterboards.ca.gov];  
scott.bohman@copperenv.com[scott.bohman@copperenv.com]; James Padgett  
(JPadgett@usaenviro.com)[JPadgett@usaenviro.com]; 'Tony Six'[TSix@usaenviro.com]; 'Gary Morgan'  
(GMorgan@usaenviro.com)[GMorgan@usaenviro.com]  
**Cc:** Doug Carey[douglas.carey@waterboards.ca.gov]; Ferguson, Scott@Waterboards  
(scott.ferguson@waterboards.ca.gov)[scott.ferguson@waterboards.ca.gov]; Witt, Darin@waterboards  
(Darin.Witt@waterboards.ca.gov)[Darin.Witt@waterboards.ca.gov]; Zentner, Taylor@Waterboards  
(taylor.zentner@waterboards.ca.gov)[taylor.zentner@waterboards.ca.gov]; Deschambault,  
Lynda[Deschambault.Lynda@epa.gov]; philthompson705@gmail.com[philthompson705@gmail.com];  
Andrew Bachman (ABachman@usaenviro.com)[ABachman@usaenviro.com]; Grice, Steve  
(CONTRACTOR)[SGrice@usaenviro.com]; David Hoffman[DHoffman@broadbentinc.com]; Souza,  
Michelle (msouza@broadbentinc.com)[msouza@broadbentinc.com]; Lombardi,  
Marc[marc.lombardi@amecfw.com]; Andrews, Andy  
(andy.andrews@amecfw.com)[andy.andrews@amecfw.com];  
abby.cazier@copperenv.com[abby.cazier@copperenv.com]; Herrscher, Russell (UNKNOWN BUSINESS  
PARTNER)[rherrscher@usaenviro.com]; Andy Slavik[andy.slavik@copperenv.com]  
**From:** Brown, Anthony R (RM)  
**Sent:** Mon 5/1/2017 4:30:05 PM  
**Subject:** HDS Spring LAS Treatment Update 05 01 2017

Hi Chris, HDS power systems are now on line and we will be ready to begin LAS water treatment and discharge from the holding pond (Pond 4 ) later this week. We will wait until the AMECFW baseline synoptic surface water sampling (simultaneous surface water sampling conditions over a large area) is completed before we begin discharge to Leviathan Creek (best estimate is currently to begin treatment on Thursday??). We plan to quickly lower the water level in Pond 4. Tony...

Anthony R Brown

Operations Project Manager – Mining

Atlantic Richfield Company

Remediation Management

4 Centerpointe Drive, Suite 200

La Palma, California USA 90623

MS Lync: 657-529-4537

Cell: 951-265-4277

- HDS Treatment System and Pond 4:

- o Continue HDS Treatment Plant spring commissioning tasks (HDS-SOP-315).
- o Completed weekly generator inspection (HDS-SOP-401).
- o Loaded two bags of lime (HDS-SOP-309).
- o Completed a generator priority change (HDS-SOP-400).
- o Repaired turbidity meter (HDS-SOP-102).
- o Verified the calibration of Pond 4 level indicator (HDS-SOP-202).
- o Douglas Disposal was onsite to deliver dumpsters (TRA).
- Permits:
  - o A Heavy Equipment permit was issued for the operation of the front end loader was closed today.
  - o A Ground Disturbance permit was issued to perform road work was closed today.
  - o A Heavy Equipment permit was issued for the tractor (“skippy”) was closed today.
  - o A SCBA permit was issued and closed to access the manholes at Aspen.